

Our Ref: MS/M110170
Test Report: MA4263/Q

10th June 2011

Rich. Klinger Dichtungstechnik GmbH & Co KG
Am Kanal 8-10
2352 Gumpoldskirchen
Austria

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SEALANTS – FLAT FACED JOINTS

5480

Klinger top-chem 2005. Red coloured PTFE, based gasket material. For use with water up to 23°C. For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 1106504


APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO KG

The Scheme reserves the right to review approval. This approval is valid between June 2011 and June 2016.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme