



Rich. Klinger
Dichtungstechnik GmbH & Co KG
Am Kanal 8-10
2352 GUMPOLDSKIRCHEN
ÖSTERREICH

Rotthäuser Str. 19
45879 Gelsenkirchen

Telephone +49 (209) 9242-0
Extension +49 (209) 9242-270
Telefax +49 (209) 9242-212
E-Mail k.stefanski@hyg.de
Internet www.hyg.de

Ref.-No.: K-179143-09-Sf/st
Contact-person: Mrs. Stefanski

Gelsenkirchen, 15.07.2009

TEST CERTIFICATE
according to the KTW-Recommendations
(Bundesgesundheitsblatt Vol. 20, page 124 ff., 1977)

(English version dated 02.07.2009, Ref.-No.: K-178610-09-Sf/st)

Prolongation with re-examination
(Ref.-No.: C-119641-04-Sf/st dated 04.08.2004)

Product: KLINGERSIL® C-4300 (green)
Test specimen: test plates
Kind of test: ☒ Product test / Permission test ☐ Supervision test

The a/m test plates made of rubber compound **KLINGERSIL® C-4300** (green) meet the requirements to the KTW-Recommendations part 1.3.13 according to the test report, dated **04.08.2004** (Ref.: **C-119641-04-Sf/st**) for the following applications and temperatures:

Applications:

Temperatures:

	cold water (23°C)	moderately hot water (60°C)	extremely hot water (90°C)
A Pipes	---	---	---
B Reservoirs / Containers	---	---	---
C Ancillaries / Fittings	---	---	---
D1 large gaskets	---	---	---
D2 small gaskets	passed	---	---

as far as the material is qualified technically.

This test certificate ending by **04.08.2014**, as far as there are no changes in the formula.

The Director of the Institute
on behalf of


(Food Chemist C. Karau)
substitutional Head of the Dept. for
water hygienic material testing



The results and conclusions exclusively refer to the investigated samples and the relevant laws.
The validity of this document expires in case of modifications in the composition of the product or the processing conditions.
This document must not be reproduced except in full, without our written approval.

