



Rotthäuser Str. 19
45879 Gelsenkirchen

Telephone +49 (209) 9242-0
Extension +49 (209) 9242-270
Telefax +49 (209) 9242-212
E-Mail k.stefanski@hyg.de
Internet www.hyg.de

Ref.-No.: K-181038-09-Sf
Contact-person: Mrs. Stefanski

Gelsenkirchen, 15.09.2009

TEST CERTIFICATE according to the KTW-Recommendations (Bundesgesundheitsblatt Vol. 20, page 124 ff., 1977)

(English version dated 07.09.2009, Ref.-No.: K-181037-09-Sf)

Applicant: Rich. Klinger
Dichtungstechnik GmbH & Co KG
Am Kanal 8-10
2352 GUMPOLDSKIRCHEN
ÖSTERREICH

Product: sealing material **KLINGER® Quantum (beige)**

Test specimen: test plates

Kind of test: ☒ Product test / Permission test ☐ Supervision test

The a/m test plates made of sealing material **KLINGER® Quantum (beige)** meet the requirements to the KTW-Recommendations part 1.3.13 according to the test report, dated **15.09.2009 (Ref.: K-181037-09-Sf)** for the following applications and temperatures:

Applications:

Temperatures:

	cold water (23°C)	moderately hot water (60°C)	extremely hot water (90°C)
A Pipes	---	---	---
B Reservoirs / Containers	---	---	---
C Ancillaries / Fittings	---	---	---
D1 large gaskets	---	---	---
D2 small gaskets	passed	---	passed

as far as the material is qualified technically.

This test certificate is valid beginning with date of issue and ending by **15.09.2014**, as far as there are no changes in the formula. After this time it can be extended for further 5 years if demanded.

The Director of the Institute
on behalf of

(Dr. rer. nat. A. Koch)
Head of the Dept. for water
hygienic material testing



The results and conclusions exclusively refer to the investigated samples and the relevant laws.

The validity of this document expires in case of modifications in the composition of the product or the processing conditions.

This document must not be reproduced except in full, without our written approval.



DAP-PL-2548.00