

Approval Number 2309552
Test Report: 122300595-0001 & PB2024001072



27th August 2024

Reinz-Dichtungs-GmbH
Reinzstrasse 3-7,
89233 Neu-Ulm,
Germany

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE

5075

'AFM 34'. Beige coloured, calendered fibre gasket material. For use with water up to 23°C.
For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio

APPROVAL NUMBER: 2309552

APPROVAL HOLDER: REINZ-DICHTUNGS-GMBH

The Scheme reserves the right to review approval.
Approval 2309552 is valid between September 2023 and September 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager