

# Confirmation

drinking water hygienic suitability in accordance with KTW-BWGL - Annex D (edition: 07.03.2022)

<b>Material:</b>	novatec® PREMIUM XP
<b>Range of application:</b>	Small area components of equipment items with a surface area in contact with water < 1 % in the equipment item (P3)
<b>Risk group:</b>	P3 - based on type testing
<b>Operating temperature:</b>	Cold - and Hot Water (23°C and 85°C)
<b>Test report:</b>	<b>KTW BWGL</b> - Hygiene Institut - Gelsenkirchen test report no. K-394204-24-Pl/st from 22 October 2024  <b>DIN EN 16421</b> (früher W270) - Hygiene Institut - Gelsenkirchen test report no. W-397301-25-Alb/Krü from 08 January 2025

We hereby confirm compliance with the requirements in accordance with the KTW BWGL - Annex D for small area components of equipment with a surface area in contact with water < 1 % for the cold and hot water range (23°C and 85°C).

The confirmation is valid up to 22 October 2029.

Bad Berneck, 21 January 2025



i.V. Dipl.-Ing. Andreas Will  
- Manager R&D Industry -



i.A. Dr. Ing. Andreas Mierzwa  
- Application Engineer -